

Secondary Containment Thresholds

The point at which your worksite requires secondary containment depends on what class of liquids you have on site, and in what quantities.

For really hazardous liquids, it is required from very low levels. For others, you are allowed to have a larger amount before secondary containment is required, while for many non-hazardous substances, little to none may be needed at all.

While not exhaustive, the below table details some of the more common classes, and at what point secondary containment is required.

Hazard Classification	Amounts Where the Need For Secondary Containment Is Triggered
Class 5.1.1A	50L
Class 5.1.1B	500L
Class 5.2A, 5.2B	10L
Class 5.2C, 5.2D	25L
Class 5.2E, 5.2F	100L
Class 6.1A, 6.1B, 6.1C	100L
Class 6.1D, 6.5A, 6.5B, 6.7A	1,000L
Class 8.2A	100L
Class 8.2B	1,000L
Class 8.2C, 8.3A	10,000L
Class 9.1A	100L
Class 9.1B, 9.1C	1,000L
Class 9.1D	10,000L

Further information including classes beyond those listed about, visit the [WorkSafe website](#).

What level of secondary containment is required if the amounts are triggered?

The below table is a summary of the requirement levels for secondary containment, as per the Health & Safety at Work (Hazardous Substances) Regulations 2017.

Requirements for Class 1-5:

Container Size	Total Pooling Potential	Secondary Containment Capacity
Up to 60L	Less than 5,000L	At least 50% of the total
	5,000L or more	2,500L or 25% of the total*
More than 60L and up to 450L	Less than 5,000L	At least that total potential
	5,000L or more	5,000L or 50% of the total*
More than 450L	Less than 5,000L	At least that total potential
	5,000L or more	5,000L or 50% of the total*

Requirements for Class 6-9:

Container Size	Total Pooling Potential	Secondary Containment Capacity
Up to 60L	Less than 20,000L	At least 25% of the total
	20,000L or more	5% of the total or 5,000L*
More than 60L and up to 450L	Less than 20,000L	25% of the total, or 110% of the capacity of the largest container*
	20,000L or more	5% of the total or 5,000L*
More than 450L	Less than 20,000L	25% of the total, or 110% of the capacity of the largest container*
	20,000L or more	5% of the total or 5,000L*

**whichever is greater*

This is a summary of Regulations 13.30, 13.31, 13.32 and 13.33 of the abovementioned Regulations and should be used as a guide in the context of all other components within it.

Content above falls under the Hazero Disclaimer, for more information please click [here](#).